

**ARNOLDS PARK, IA  
SPECIAL SESSION  
OCTOBER 7, 2015**

**4:00 P.M.**

COUNCIL PRESENT: Jensen, Richter, Watters, Adams. Mayor Hussong presided.

COUNCIL ABSENT: Christensen.

OTHERS PRESENT: Jeff Rose, Brad Beck, Julie Fillenwarth, Rick Heinrichs, Wanda Thielen.

STORM SEWER INVESTIGATION: Julie Fillenwarth addressed the Council regarding the deterioration of the City storm sewer west of Fillenwarth Beach Resort caused by heavy rainfall in August. Brad Beck, Beck Engineering reported on Fillenwarth's behalf regarding the storm sewer. Brad recommended three solutions for repairing the storm sewer. The first option is to reconstruct the entire storm sewer from Lakeshore Drive to West Okoboji Lake. This option would possibly require an easement from Ridgeview Shores Condominium and would not be completed until the Spring of 2016. The second option would be constructing a pipe liner inside the existing storm sewer. This would involve inverting a felt sock throughout the existing storm sewer with steam. This would be less costly and could be completed this fall.

The third option would be filling the existing void with flowable mortar to stabilize the area. This would not reduce the velocity through the pipe. This would be less costly and could be completed this fall. A lengthy discussion followed. Jeff Rose and Rick Heinrichs stated there is surface damage as well. Julie Fillenwarth felt surface damage is not an issue. Jeff Rose stated the liner would be a good option. Thielen agreed with that option. Motion approving Option No. 2- Construction of a Cured-in-Place Pipe Liner with the cost not to exceed \$40,000. Richter/Adams. Ayes; four. Nays; none. Christensen absent.

Motion to adjourn. Watters/Richter. Ayes; four. Nays; none. Christensen absent. Mayor Hussong declared the meeting adjourned at 4:26 P.M.

---

Mayor

---

City Clerk